

FYRAX™

Fire Equipments



JAS-ANZ



CHIRAG INDUSTRIES (AN ISO 9001:2008 CERTIFIED COMPANY)

Works: Plot No: 52,53,54 HSIIDC Ind Estate, Murthal
Dist: Sonipat, Haryana, India Ph: 0130-248-3257 email: chiragindustries2005@yahoo.com

Date :-12/09/2020

REFILLS CERTIFICATE

TEST CERTIFICATE FOR : 4.5 KG CO2 TYPE FIRE EXTINGUISHERS
HYDRO TEST : 35KGF/CM2
MANUFACTURER : CHIRAG INDUSTRIES, HARYANA (INDIA)
NAME OF BUILDING : GITANJALI TEACHERS
TRAINING COLLEGE
NAME OF OWNER : PIJUSH KANTI PAUL
ADDRESS : VILL + P.O- CHOA, P.S-
HARIHARPARA, DIST-MURSHIDABAD
TESTED BY : CHIRAG INDUSTRIES, HARYANA (INDIA)
TESTING DATE : 07.09.2020
FIRE RATING : 2A & 21B
QUANTITY : 6- NOS.
SERIAL NUMBER : BEARING SERIAL NO (15253 TO 15840) (15841 TO 17098)
(18385 TO 18800)

DECLARATION:

The above mentioned goods are warranted against defect in material and workmanship under normal use. The warranty is limited to a period of 12 (TWELVE) MONTHS FROM THE DATE OF REFILLS whichever is earlier. The company's obligation shall be limited to rectifying, repairing or replace defective parts EX- Factory, provided the purchase has given immediate written notice upon the discovery of such defect. The company will be automatically relieved of its obligation in case the unit is open or any changes/repairs are made without its prior approval within the guarantee period. These warranty any and every other obligation for loss or damage direct or consequential or for any accident resulting the defective and faulty workmanship.


FOR CHIRAG INDUSTRIES
Authorized Signatory
P. Pal
Karnalpur
Nadia
12/9/20

Works: Plot No: 52,53,54 HSIIDC Ind Estate, Murthal
Dist: Sonipat, Haryana, India Ph: 0130-248-3257 email: chiragindustries2005@yahoo.com

Date :-12/09/2020

REFILLS CERTIFICATE

TEST CERTIFICATE FOR : 5 KG ABC TYPE FIRE EXTINGUISHERS
HYDRO TEST : 35KGF/CM2
MANUFACTURER : CHIRAG INDUSTRIES, HARYANA (INDIA)
NAME OF BUILDING : GITANJALI TEACHERS
TRAINING COLLEGE
NAME OF OWNER : PIJUSH KANTI PAUL
ADDRESS : VILL + P.O- CHOA, P.S-
HARIHARPARA, DIST-MURSHIDABAD
TESTED BY : CHIRAG INDUSTRIES, HARYANA (INDIA)
TESTING DATE : 07.09.2020
FIRE RATING : 2A & 21B
QUANTITY ; 9- NOS.
SERIAL NUMBER : BEARING SERIAL NO (15253 TO 15840) (15841 TO 17098)
(18385 TO 18800)

DECLARATION:

The above mentioned goods are warranted against defect in material and workmanship under normal use. The warranty is limited to a period of 12 (TWELVE) MONTHS FROM THE DATE OF REFILLS whichever is earlier. The company's obligation shall be limited to rectifying, repairing or replace defective parts EX- Factory, provided the purchase has given immediate written notice upon the discovery of such defect. The company will be automatically relieved of its obligation in case the unit is open or any changes/repairs are made without its prior approval within the guarantee period. These warranty any and every other obligation for loss or damage direct or consequential or for any accident resulting the defective and faulty workmanship.

FOR CHIRAG INDUSTRIES
Authorized Signatory
12/09/20

FYRAX™

Fire Equipments



JAS-ANZ



CHIRAG INDUSTRIES (AN ISO 9001:2008 CERTIFIED COMPANY)

Works: Plot No: 52,53,54 HSIIDC Ind Estate, Murthal

Dist: Sonipat, Haryana, India Ph: 0130-248-3257 email: chiragindustries2005@yahoo.com

Date :-12/09/2020

REFILLS CERTIFICATE

TEST CERTIFICATE FOR : 9 LTRS A (WATER) TYPE FIRE EXTINGUISHERS

HYDRO TEST : 35KGF/CM2

MANUFACTURER : CHIRAG INDUSTRIES, HARYANA (INDIA)

NAME OF BUILDING : GITANJALI TEACHERS
TRAINING COLLEGE

NAME OF OWNER : PIJUSH KANTI PAUL

ADDRESS : VILL + P.O- CHOA, P.S-
HARIHARPARA, DIST-MURSHIDABAD

TESTED BY : CHIRAG INDUSTRIES, HARYANA (INDIA)

TESTING DATE : 07.09.2020

FIRE RATING : 2A & 21B

QUANTITY ; 5- NOS.

SERIAL NUMBER : BEARING SERIAL NO (15253 TO 15840) (15841 TO 17098)
(18385 TO 18800)

DECLARATION:

The above mentioned goods are warranted against defect in material and workmanship under normal use. The warranty is limited to a period of 12 (TWELVE) MONTHS FROM THE DATE OF REFILLS whichever is earlier. The company's obligation shall be limited to rectifying, repairing or replace defective parts EX- Factory, provided the purchase has given immediate written notice upon the discovery of such defect. The company will be automatically relieved of its obligation in case the unit is open or any changes/repairs are made without its prior approval within the guarantee period. These warranty any and every other obligation for loss or damage direct or consequential or for any accident resulting the defective and faulty workmanship.

FOR CHIRAG INDUSTRIES
Nadia
Authorized Signatory

12/09/20

FYRAX™

Fire Equipments



CHIRAG INDUSTRIES (AN ISO 9001:2008 CERTIFIED COMPANY)

Works: Plot No: 52,53,54 HSIIDC Ind Estate, Murthal
Dist: Sonipat, Haryana, India Ph: 0130-248-3257 email: chiragindustries2005@yahoo.com

Date :-12/09/2020

REFILLS CERTIFICATE

TEST CERTIFICATE FOR : 5 KG BC TYPE FIRE EXTINGUISHERS
HYDRO TEST : 35KGF/CM2
MANUFACTURER : CHIRAG INDUSTRIES, HARYANA (INDIA)
NAME OF BUILDING : GITANJALI TEACHERS
TRAINING COLLEGE
NAME OF OWNER : PIJUSH KANTI PAUL
ADDRESS : VILL + P.O- CHOA, P.S-
HARIHARPARA, DIST-MURSHIDABAD
TESTED BY : CHIRAG INDUSTRIES, HARYANA (INDIA)
TESTING DATE : 07.09.2020
FIRE RATING : 2A & 21B
QUANTITY ; 2- NOS.
SERIAL NUMBER : BEARING SERIAL NO (15253 TO 15840) (15841 TO 17098)
(18385 TO 18800)

DECLARATION:

The above mentioned goods are warranted against defect in material and workmanship under normal use. The warranty is limited to a period of 12 (TWELVE) MONTHS FROM THE DATE OF REFILLS whichever is earlier. The company's obligation shall be limited to rectifying, repairing or replace defective parts EX- Factory, provided the purchase has given immediate written notice upon the discovery of such defect. The company will be automatically relieved of its obligation in case the unit is open or any changes/repairs are made without its prior approval within the guarantee period. These warranty any and every other obligation for loss or damage direct or consequential or for any accident resulting the defective and faulty workmanship.

